



| APPROX WEIGHTS | |
|----------------------------------------|---------|
| • RISER #1 (BASED ON DN1800 x 900) : | 2750 Kg |
| • RISER #2 (DN1800 x 1500 INCL DECK) : | 2100 Kg |
| • CONCRETE LID (DN1800 x 200 THICK) : | 1800 Kg |

| TO BE COMPLETED BY CUSTOMER / CONTRACTOR | | | |
|-----------------------------------------------------------------|-------------------------------|-------------------------------------|-----------------------------------------|
| COMPANY : | | P.O. NUMBER : | |
| SITE ADDRESS : | | | |
| SITE CONTACT & PHONE : | | | |
| PREFERRED DELIVERY DATE (TBC SW360) : | | | |
| FILTER REFERENCE (IF APPLICABLE) : | | LID LEVEL (INPUT REQUIRED) : | |
| INLET PIPE DATA (DN375 RCRRJ-MAX) : (DN375 PVC-MAX) | IL : | DIA : | MATERIAL : |
| OUTLET PIPE DATA (DN375 RCRRJ-MAX) : (DN375 PVC-MAX) | IL : | DIA : | MATERIAL : |
| OUTLET PIPE ORIENTATION : (CIRCLE 180° OR INPUT REQUIREMENT) | AS DRAWN : 180° FROM INLET | CLOCKWISE FROM INLET : (60° MIN) | ANTICLOCKWISE FROM INLET : (60° MIN) |
| COMPLETED BY : | SIGNED : | DATE : | |

| TO BE COMPLETED BY SW360 | | | |
|-------------------------------------------------------------------------------------|-------------------------------------------------------|--------|------------------------------------------------------|
| DRIVING HEAD (DH) (CIRCLE REQUIREMENT OR INPUT CUSTOM VALUE) : | 305 mm | 460 mm | CUSTOM DRIVING HEAD : (INPUT DETAILS IF REQUIRED) |
| DEPTH TO INVERT (DTI) CHECK : (CALCULATE AND RECORD) : | INLET / OUTLET IL CHECK : (CALCULATE AND RECORD) : | | No. OF FILTERS : |
| ACCESS COVER : 900 x 900 WEBFORGE / CLASS D : (SUPPLIED UNLESS STATED OTHERWISE) | DETAILS OF OTHER : (IF REQUIRED) | | |
| COMPLETED BY : | SIGNED : | DATE : | |

| NOTES : |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1. CONCRETE MANHOLE RISER UNITS FITTED WITH SWIFTLIFT ANCHOR POINTS (QTY 2). DO NOT EXCEED 60 DEGREE LIFT ANGLE. CONCRETE LID FITTED WITH SWIFTLIFT ANCHOR POINTS (QTY 4). |
| 2. UNIT SUPPLIED WITH BOTH INLET AND OUTLET CORE DRILLED. |
| 3. SEALING / GROUTING OF MANHOLE COMPONENTS AND PIPES BY CONTRACTOR. ENSURING LOCAL CODES AND REGULATIONS ARE COMPLIED WITH. |
| 4. ANY RISERS REQUIRED TO INCREASE THE DEPTH TO INVERT (DTI) FROM THAT AS DRAWN TO BE SUPPLIED BY THE CONTRACTOR. |
| 5. FOR A DTI EXCEEDING 5m PLEASE CONTACT 0800STORMWATER . |
| 6. BACKFILL, BEDDING AND BUOYANCY DESIGN BY ENGINEER OF RECORD. |
| 7. CONCRETE MANHOLE RISERS ARE DESIGNED AND MANUFACTURED IN ACCORDANCE WITH AS/NZS 4058 : 2007 |
| 8. CONCRETE MANHOLE BASES ARE DESIGNED AND MANUFACTURED IN ACCORDANCE WITH NZS 3101 : 2006 AND NZS 3109 : 1997 |
| 9. CONCRETE LID DESIGNED AND MANUFACTURED TO HN-HO-72. |
| 10. FILTERS AND MAINTENANCE ACCESS WALL (MAW) TO BE INSTALLED DURING COMMISSIONING BY STORMWATER360. |
| 11. COMMISSIONING TO OCCUR ONLY WHEN CONSTRUCTION IS COMPLETE, AND SITE IS CLEAN. |
| 12. CONTRACTOR TO ENSURE MANHOLE IS CLEAN FROM SITE RUN-OFF PRIOR TO COMMISSIONING. |
| 13. CONTACT 0800STORMWATER FOR COMMISSIONING OR ANY REQUIREMENTS OUTSIDE THIS DRAWING. |

| DATA FOR PRODUCTION ONLY (COMPLETED BY SW360) | | | |
|--------------------------------------------------------------------------------|--------------|--------------------------------------------|---------------------------------------------|
| OUT (Ø) OUTLET CORE Ø | MAX Ø 500 | OUT (HEIGHT) = 1010 mm - 0.5 PIPE ID | IN (Ø) OUTLET CORE Ø |
| | | | MAX Ø 500 |
| INLET TO OUTLET DISTANCE : WRAP MEASUREMENT FROM C/L INLET TO C/L OUTLET | | = (ANGLE) x (3.14 x RISER OD) 360 | IN (HEIGHT) = OUT (HEIGHT) - Δ INVERT |
| COMPLETED BY : | | SIGNED : | DATE : |



0800 STORMWATER

sales@stormwater360.co.nz

www.stormwater360.co.nz

CONDITION OF USE

© STORMWATER360 2019
Any unauthorised
reproduction of this drawing
in part or in full is prohibited

JELLYFISH® FILTER
STORMWATER MEMBRANE FILTER
DN1800 / 27" FILTERS 6 + 1 / OFFLINE / TRAFFICABLE
GENERAL ARRANGEMENT

SCALE : N.T.S. DRG No : JF-MH-27-1800-T-OFF-20 REV : 1 DATE : 10.04.19

| JOB NO : | REV | REVISION DETAIL | DATE |
|-----------|-----|-----------------|----------|
| PROJECT : | 0 | FIRST DRAFT | 10.04.19 |
| DRN : | 1 | FORMULA REV | 12.08.19 |
| CKD : | | | |