



APPROX WEIGHTS

- RISER #1 (BASED ON DN1050 x 1200) : 1350 Kg
- RISER #2 (DN1050 x 1500 INCL DECK) : 970 Kg

TO BE COMPLETED BY CUSTOMER / CONTRACTOR

COMPANY : _____ P.O. NUMBER : _____

SITE ADDRESS : _____

SITE CONTACT & PHONE : _____

PREFERRED DELIVERY DATE (TBC SW360) : _____

FILTER REFERENCE (IF APPLICABLE) : _____ LID LEVEL (INPUT REQUIRED) : _____

INLET PIPE DATA (DN225 RGRRL-MAX) : (DN300 PVC-MAX)	IL :	DIA :	MATERIAL :
OUTLET PIPE DATA (DN225 RGRRL-MAX) : (DN300 PVC-MAX)	IL :	DIA :	MATERIAL :
OUTLET PIPE ORIENTATION : (CIRCLE 180° OR INPUT REQUIREMENT)	AS DRAWN : 180° FROM INLET	CLOCKWISE FROM INLET : (60° MIN)	ANTICLOCKWISE FROM INLET : (60° MIN)

COMPLETED BY : _____ SIGNED : _____ DATE : _____

TO BE COMPLETED BY SW360

DRIVING HEAD (DH)
(CIRCLE REQUIREMENT OR INPUT CUSTOM VALUE) : 229 mm CUSTOM DRIVING HEAD :
(INPUT DETAILS IF REQUIRED)

DEPTH TO INVERT (DTI) CHECK : _____ INLET / OUTLET IL CHECK : _____
(CALCULATE AND RECORD) : (CALCULATE AND RECORD) :

ACCESS COVER : DN1050 CHECKER PLATE / NON TRAFFICABLE (SUPPLIED UNLESS STATED OTHERWISE) DETAILS OF OTHER : (IF REQUIRED)

COMPLETED BY : _____ SIGNED : _____ DATE : _____

- NOTES :**
1. CONCRETE MANHOLE RISER UNITS FITTED WITH SWIFTLIFT ANCHOR POINTS (QTY 2). DO NOT EXCEED 60 DEGREE LIFT ANGLE.
 2. UNIT SUPPLIED WITH BOTH INLET AND OUTLET CORE DRILLED.
 3. SEALING / GROUING OF MANHOLE COMPONENTS AND PIPES BY CONTRACTOR. ENSURING LOCAL CODES AND REGULATIONS ARE COMPLIED WITH.
 4. ANY RISERS REQUIRED TO INCREASE THE DEPTH TO INVERT (DTI) FROM THAT AS DRAWN TO BE SUPPLIED BY THE CONTRACTOR.
 5. BACKFILL, BEDDING AND BUOYANCY DESIGN BY ENGINEER OF RECORD.
 6. CONCRETE MANHOLE RISERS ARE DESIGNED AND MANUFACTURED IN ACCORDANCE WITH AS/NZS 4058 : 2007
 7. CONCRETE MANHOLE BASES ARE DESIGNED AND MANUFACTURED IN ACCORDANCE WITH NZS 3101 : 2006 AND NZS 3109 : 1997
 8. FILTERS AND MAINTENANCE ACCESS WALL (MAW) TO BE INSTALLED DURING COMMISSIONING BY STORMWATER360.
 9. COMMISSIONING TO OCCUR ONLY WHEN CONSTRUCTION IS COMPLETE, AND SITE IS CLEAN.
 10. CONTRACTOR TO ENSURE MANHOLE IS CLEAN FROM SITE RUN-OFF PRIOR TO COMMISSIONING.
 11. CONTACT **0800STORMWATER** FOR COMMISSIONING OR ANY REQUIREMENTS OUTSIDE THIS DRAWING.

DATA FOR PRODUCTION ONLY (COMPLETED BY SW360)

OUT (Ø)	MAX Ø 350	OUT (HEIGHT)	OUTLET CORE Ø	IN (Ø)	MAX Ø 350	IN (HEIGHT)	IN (HEIGHT)
OUTLET CORE Ø	Ø 350	OUTLET CORE Ø	- 0.5 PIPE ID	OUTLET CORE Ø	Ø 350	IN (HEIGHT)	IN (HEIGHT)

INLET TO OUTLET DISTANCE : _____ = (ANGLE) x (3.14 x RISER OD)
WRAP MEASUREMENT FROM C/L INLET TO C/L OUTLET 360

COMPLETED BY : _____ SIGNED : _____ DATE : _____

Stormwater360
BETWEEN SKY AND SEA

0800 STORMWATER
sales@stormwater360.co.nz
www.stormwater360.co.nz

CONDITION OF USE

© STORMWATER360 2020
Any unauthorised reproduction of this drawing in part or in full is prohibited

STORMWATER MEMBRANE FILTER
40" / DN1050 / NON-TRAFFICABLE / ONLINE
GENERAL ARRANGEMENT

JELL YFISH@FILTER

SCALE : N.T.S.	DRG No : JF-MH-40-1050-NT-ON-20	REV : 0	DATE : 20/4/20	CKD : K.J.	17/4/20
----------------	---------------------------------	---------	----------------	------------	---------

JOB NO. :	REV	REVISION DETAIL	DATE
PROJECT :	0	APPROVED	20/4/20
DRN :	G.S.	14/4/20	
CKD :	K.J.	17/4/20	

