

TO BE COMPLETED BY CUSTOMER / CONTRACTOR										
COMPANY:	P.O. NUMBER :									
SITE ADDRESS:										
SITE CONTACT & PHONE :										
PREFERRED DELIVERY DATE (TBC SW360):										
FILTER REFERENCE (IF APPLICABLE):			VEL (INPUT REQUIRE	D) :						
INLET PIPE DATA (DN225 RCRRJ-MAX) : (DN300 PVC-MAX)	IL:	DIA:		MATERIAL :						
OUTLET PIPE DATA (DN225 RCRRJ-MAX) : (DN300 PVC-MAX)	IL:	DIA:		MATERIAL :						
OUTLET PIPE ORIENTATION : (CIRCLE 180° OR INPUT REQUIREMENT)	AS DRAWN : 180° FROM INLET	CLOCKWISE FROM INLET: (60° MIN)		ANTICLOCKWISE FROM INLET: (60° MIN)						
COMPLETED BY :	SIGNED:			DATE :						

TO BE COMPLETED BY SW360								
DRIVING HEAD (DH) (CIRCLE REQUIREMENT OR INPUT CUSTOM VALUE):		305 mm	460 mm	CUSTOM DRIVING HEAD : (INPUT DETAILS IF REQUIRED)				
DEPTH TO INVERT (DTI) CHECK: (CALCULATE AND RECORD):	INLET / OUTLET IL CHECK : (CALCULATE AND RECORD) :				No. OF FILTERS :			
ACCESS COVER: 900 x 900 WEBFORGE / CLASS D: (SUPPLIED UNLESS STATED OTHERWISE)			DETAILS OF OTHER : (IF REQUIRED)					
COMPLETED BY :			SIGNED:		DA <sup>-</sup>	TE:		

## NOTES:

- 1. CONCRETE MANHOLE RISER UNITS FITTED WITH SWIFTLIFT ANCHOR POINTS (QTY 2). DO NOT EXCEED 60 DEGREE LIFT ANGLE. CONCRETE LID FITTED WITH SWIFTLIFT ANCHOR POINTS (QTY 4).
- 2. UNIT SUPPLIED WITH BOTH INLET AND OUTLET CORE DRILLED.
- 3. SEALING / GROUTING OF MANHOLE COMPONENTS AND PIPES BY CONTRACTOR. ENSURING LOCAL CODES AND REGULATIONS ARE COMPLIED WITH.
- 4. ANY RISERS REQUIRED TO INCREASE THE DEPTH TO INVERT (DTI) FROM THAT AS DRAWN TO BE SUPPLIED BY THE CONTRACTOR.
- 5. FOR A DTI EXCEEDING 5m PLEASE CONTACT 0800STORMWATER.
- 6. BACKFILL, BEDDING AND BUOYANCY DESIGN BY ENGINEER OF RECORD.
- 7. CONCRETE MANHOLE RISERS ARE DESIGNED AND MANUFACTURED IN ACCORDANCE WITH AS/NZS 4058 : 2007
- 8. CONCRETE MANHOLE BASES ARE DESIGNED AND MANUFACTURED IN ACCORDANCE WITH NZS 3101 : 2006 AND NZS 3109 : 1997
- 9. CONCRETE LID DESIGNED AND MANUFACTURED TO HN-HO-72.
- 10. FILTERS AND MAINTENANCE ACCESS WALL (MAW) TO BE INSTALLED DURING COMMISSIONING BY STORMWATER360.
- 11. COMMISSIONING TO OCCUR ONLY WHEN CONSTRUCTION IS COMPLETE, AND SITE IS CLEAN.
- 12. CONTRACTOR TO ENSURE MANHOLE IS CLEAN FROM SITE RUN-OFF PRIOR TO COMMISSIONING.
- 13. CONTACT **0800STORMWATER** FOR COMMISSIONING OR ANY REQUIREMENTS OUTSIDE THIS DRAWING.

DATA FOR PRODUCTION ONLY (COMPLETED BY SW360)										
OUT (Ø) OUTLET CORE Ø	MAX Ø 350	OUT (HEIGHT) = 980 mm - 0.5 PIPE ID		IN (Ø) OUTLET CORE Ø	MAX Ø 350	IN (HEIGHT) = OUT (HEIGHT) - Δ INVERT				
INLET TO OUTLE WRAP MEASUREM C/L INLET TO C/L O										
COMPLETED BY:			SIGNED :		DATE :					



o800 STORMWATER

CONDITION OF USE

Sales@stormwater360.co.nz

www.stormwater360.co.nz

CONDITION OF USE

STORMWATER360 2019

Any unauthorised reproduction of this drawing in part or in full is prohibited

JELLYFISH® FILTER
STORMWATER MEMBRANE FILTER
DN1200 / 40" FILTERS 2 + 1 / ONLINE / TRAFFICABLE
GENERAL ARRANGEMENT

SCALE: N.T.S. DRG No: JF-MH-40-1200-T-ON-20 REV: 1 DATE: 25.05.19

 JOB NO :
 REV
 REVISION DETAIL
 DATE

 PROJECT :
 0
 APPROVED
 25.05.19

 DRN :
 R.P.
 25.05.19
 1
 FORMULA REV
 12.08.19

 CKD :
 G.S.
 25.05.19
 .
 .
 .
 .