



TO BE COMPLETED BY CUSTOMER / CONTRACTOR

COMPANY : _____ P.O. NUMBER : _____

SITE ADDRESS : _____

SITE CONTACT & PHONE : _____

PREFERRED DELIVERY DATE (TBC SW360) : _____

STORMFILTER REFERENCE (IF APPLICABLE) : _____

OUTLET HOLE Ø (CIRCLE) : (TYPICAL PIPE MATERIAL)	Ø 275 (DN225 PVC)	Ø 300 (DN225 RRJ)	Ø 350 (DN300 PVC)	Ø 400 (DN300 RRJ)	Ø 500 (DN375 RRJ)	Ø 600 (DN450 RRJ)
--	-----------------------------	-----------------------------	-----------------------------	-----------------------------	-----------------------------	-----------------------------

LID LEVEL (RL) : _____ OUTLET PIPE (IL) : _____ DTI : _____

COMPLETED BY : _____ SIGNED : _____ DATE : _____

TO BE COMPLETED BY SW360

SW360 PRODUCT CODE : _____

MEDIA TYPE (CIRCLE ONE) :	PERLITE	ZPG	OTHER :
---------------------------	---------	-----	---------

CARTRIDGE QTY (STATE) : _____ PRE-INSTALLATION (Y/N) : _____

SP FLOW RATE (CIRCLE ONE) :	FULL (Ø 27.6 ID) BLACK/MUSTARD	3 QTR (Ø 24.0 ID) WHITE/OPAL	HALF (Ø 19.7 ID) GREEN	OTHER :
-----------------------------	-----------------------------------	---------------------------------	---------------------------	---------

ACCESS COVER (CIRCLE ONE) : _____ 900 x 900 WEB-FORGE / CLASS D OTHER : _____

COMPLETED BY : _____ SIGNED : _____ DATE : _____

SW360 PRODUCTION DATA

OUTLET HOLE DETAILS :
(CIRCLE REQUIREMENT)

OUTLET HOLE Ø	DIM A
275	190
300	180
350	220
400	225
500	260
600	315

DWG ISSUE No. : _____

REQUIRED DATE : _____

- NOTES**
- MANHOLE UNIT FITTED WITH SWIFTLIFT ANCHOR POINTS (QTY 2). DO NOT EXCEED 60 DEGREE LIFT ANGLE. CONCRETE LID FITTED WITH SWIFTLIFT ANCHOR POINTS (QTY 4).
 - UNIT SUPPLIED WITH OUTLET CORE DRILLED. INLET/S CORE DRILLED ON SITE BY OTHERS WITHIN RANGE SHOWN ON DRAWING.
 - SEALING / GROUTING OF MANHOLE COMPONENTS AND PIPES BY CONTRACTOR. ENSURING LOCAL CODES AND REGULATIONS ARE COMPLIED WITH.
 - ANY RISERS REQUIRED TO INCREASE THE DEPTH TO INVERT (DTI) FROM THAT AS DRAWN TO BE SUPPLIED BY THE CONTRACTOR.
 - FOR A DTI EXCEEDING 5m PLEASE CONTACT **0800STORMWATER**.
 - CONTRACTOR TO TAKE APPROPRIATE MEASURES TO PROTECT CARTRIDGES FROM CONSTRUCTION RELATED EROSION RUNOFF.
 - BACKFILL, BEDDING AND BUOYANCY DESIGN BY ENGINEER OF RECORD
 - QTY OF CARTRIDGES BY ENGINEER OF RECORD.
 - CONCRETE MANHOLE RISERS ARE DESIGNED AND MANUFACTURED IN ACCORDANCE WITH AS/NZS 4058 : 2007
 - CONCRETE MANHOLE BASES ARE DESIGNED AND MANUFACTURED IN ACCORDANCE WITH NZS 3101 : 2006 & NZS 3109 : 1997
 - CONCRETE LID DESIGNED AND MANUFACTURED TO HN-HO-72
 - FOR REQUIREMENTS OUTSIDE OF DRAWING SPECIFICATIONS PLEASE CONTACT **0800STORMWATER**.

APPROX WEIGHTS

MANHOLE SECTION INCLUDING CARTRIDGES : **5200 Kg**
(AS DELIVERED, BASED ON QTY 10 ZPG CARTS)

LID WEIGHT : **2500 Kg**