



TO BE COMPLETED BY CUSTOMER / CONTRACTOR

COMPANY :	P.O. NUMBER :		
SITE ADDRESS :			
SITE CONTACT & PHONE :			
PREFERRED DELIVERY DATE (TBC SW360) :			
STORMFILTER REFERENCE (IF APPLICABLE) :			
INLET PIPE Ø :	PIPE MATERIAL :	CORE DRILL Ø :	INLET (IL) :
OUTLET PIPE Ø :	PIPE MATERIAL :	CORE DRILL Ø :	OUTLET (IL) :
LID LEVEL (RL) :	DTI :		
COMPLETED BY :	SIGNED :	DATE :	

TO BE COMPLETED BY SW360

SW360 PRODUCT CODE :	PERLITE	ZPG	OTHER :
MEDIA TYPE (CIRCLE ONE) :	PRE-INSTALLATION (Y/N) :		
CARTRIDGE QTY (STATE) :			
SP FLOW RATE (CIRCLE ONE) :	FULL (Ø 27.6 ID)	3 QTR (Ø 24.0 ID)	OTHER :
	BLACKMUSTARD	WHITEOPAL	GREEN
ACCESS COVERS (CIRCLE ONE) :	AS DRAWN - YES or NO		OTHER :
COMPLETED BY :	SIGNED :	DATE :	

APPROX WEIGHTS

VAULT WEIGHT: 23300 Kg (EMPTY)
 VAULT WEIGHT: 24850 Kg (WITH 31 x ZPG CARTS FITTED)
 LID WEIGHT: 8100 Kg

NOTES

- SW360 TO CONFIRM WEIGHTS AND LIFTING DETAILS PRIOR TO DELIVERY.
- UNIT SUPPLIED WITH INLET & OUTLET HOLES PRE-CORED.
- INLET AND OUTLET PIPES BY OTHERS.
- SEALING / GROUTING OF CONCRETE LID AND PIPES BY CONTRACTOR, ENSURING LOCAL CODES AND REGULATIONS ARE COMPLIED WITH.
- RISERS REQUIRED FROM VAULT LID TO ACCESS COVERS (FINISHED SURFACE LEVEL) SUPPLIED BY THE CONTRACTOR. CONTACT **0800STORMWATER** FOR RECOMMENDATIONS.
- CONTRACTOR TO TAKE APPROPRIATE MEASURES TO PROTECT CARTRIDGES FROM CONSTRUCTION RELATED EROSION RUNOFF. BACKFILL, BEDDING AND BUOYANCY DESIGN BY ENGINEER OF RECORD.
- QTY OF CARTRIDGES BY ENGINEER OF RECORD.
- CONCRETE VAULT AND LID DESIGNED AND MANUFACTURED TO HN-HO-72
- DESIGN CHECK REQUIRED WHEN COVER ABOVE LID EXCEEDS 1.0M
- OTHER CONFIGURATIONS ARE POSSIBLE. FOR REQUIREMENTS OUTSIDE OF DRAWING SPECIFICATIONS PLEASE CONTACT **0800STORMWATER**.



0800 STORMWATER
 sales@stormwater360.co.nz
 www.stormwater360.co.nz

CONDITION OF USE
 © STORMWATER360 2020
 Any unauthorised reproduction of this drawing in part or in full is prohibited

STORMFILTER® PEAK DIVERSION
 OFF-LINE CARTRIDGE FILTRATION SYSTEM
 31 x 69cm CART PD VAULT (LEFT INLET)
 GENERAL ARRANGEMENT
 SCALE : N.T.S. DRG No : SF-VPD-69-4730-L-20
 REV : 1 DATE : 02/04/20

JOB NO :	REV	REVISION DETAIL	DATE
PROJECT :	1	WEIGHTS ADDED	02/04/20
DRN :	0	APPROVED	17/03/20
CKD :	K.J.		17/03/20